



ठाणे महानगरपालिका, ठाणे.

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग, चंदनवाडी पांचपाखाडी, ठाणे ४०० ६०२.

THE MUNICIPAL CORPORATION OF THE CITY OF THANE

Ref/T.M.C./CFO/M - 683

Date - 05/10/2026

FIRE SAFETY CERTIFICATE

Certified that the Sharda Education Society's AMBAR INTERNATIONAL SCHOOL (name of the building or Premises) at Sector No - 88, Plot bearing Sr. Nos. 88, Hissa No. 5/2 at Village - Dhokali Thane. (address) Comprised of BASEMENT + Ground floors + 7 Floor owned / occupied by Sharda Education Society's AMBAR INTERNATIONAL SCHOOL, Sector No - 88, Plot bearing Sr. Nos. 88, Hissa No. 5/2 at Village - Dhokali Thane. (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 29/05/2026 (date of inspection) in the presence of Mr. Santosh Warick (M/s VAISHALI ENTERPRISES) and that the building / premises is fit for occupancy up to classes Nursery to 12th Standard With effect from 05.10.2026 for a period of One year in accordance with rule and subject to compliance of specific conditions as appended:-

- | | | | | |
|--------------------------|--------|-------|----------------------------------|-------|
| 1. Fire Extinguisher | 06 Kg | - Yes | 8. Sprinkler Pump 75 hp | - Yes |
| 2. Co2 Fire Extinguisher | 4.5 Kg | - Yes | 9. Booster Pump 12.5 hp | - Yes |
| 3. Fire Alarm Panel | | - Yes | 10.. Double Headed Hydrant Valve | - Yes |
| 4. Smoke Detector | | - Yes | 11. Hose Reel | - Yes |
| 5. MCP Cum Hooter | | - Yes | 12. Double Hose Box | - Yes |
| 6. Main Pump 75 hp | | - Yes | 13. Sprinkler | - Yes |
| 7. Diesel Pump 72 hp | | - Yes | 14. Fire Brigade Inlet | - Yes |

Issued on 05/10/2026 (date of issue) at Thane (place) by

Signature with seal: _____

Name

: Mr. Girish. M. Zalke

Designation

: Chief Fire Officer, Thane

Name & Address of Department/ Office

: Chief Fire Officer, Thane
Municipal Fire Brigade, Thane.



To

Sharda Education Society's AMBAR INTERNATIONAL SCHOOL,

Sector No - 88, Plot bearing Sr. Nos. 88, Hissa No. 5/2 at Village = Dhokali Thane.

(Name & Address of the Institution)

ENDORSEMENT

The no objection certificate issued by Fire Service stand cancelled and annulled due to negligence of any fire safety norms laid by state government.

This Fire Safety Certificate Subject to Submission of Form B For Every Six Month as per Maharashtra Fire Prevention & Life Safety Act 2006.

(Name and designation of the authorized signatory)