



ठाणे महानगरपालिका

THE MUNICIPAL CORPORATION OF THE CITY OF THANE

प्रदूषण नियंत्रण कक्ष

POLLUTION CONTROL CELL



E-mail : pccmtmc@gmail.com

महानगरपालिका भवन, सरसेनानी जनरल अरुणकुमार वैद्य मार्ग,
चंदनवाडी, पांचपाखडी, ठाणे - ४००६०२

Tel: +91-22-25362916

Recognition of Lab under EPA 1986, notified in the Govt. of India Gazette No. 952 dated 6th November 2002 vide notification No. S.O.1168(E) dt.01.06.02

Vakratunda Laboratory, Bhakti Mandir Road, Hari Niwas ,Naupada Thane. Tel. No. : 25375711

Ref./T.M.C./P.C.C./V.Lab - 1035
Sample No. : S312

Date : 15 July 2026

Water Analysis Report

TMC/PCC/20/RO

Name Of the Organisation : M/S Amber International School (Dnyansadhana Vidyaniketan English Medium School)

Address : Next To Highland Park, Near TMC Water Tank, Dhokali Thane (W)

E_mail ID : dvidyaniketan@gmail.com

Date of receiving Sample : 14 July 2026

Sample Collected by : Prabhakar Sonawale

Type of Water Sample : Storage Drinking (Tank) -2nd sample

Parameters	Results	Limits as per IS 10500
pH	7.10	6.5 - 8.5
Free Residual Chlorine	0.2	1 ppm
Turbidity	1.0	5 NTU
Chloride	10.0	250 mg/L
Total Hardness	15.0	300 mg/L
Total Coliform Bacteria (MPN)	0.00	0/100 mL
F-Coli	Absent	0/100 mL
E-Coli	Absent	0/100 mL

All results are in ppm except pH .

Remark : The Sample is Microbiologically & Chemically Potable.

Prepared By

15-Jul-26

Sanchita S. Kadlak

Thane Municipal Corporation, Thane

Authorised by

15-Jul-26

Nirmitee N. Salgaonkar

Thane Municipal Corporation, Thane

This is the analysis report of the Storage Drinking (Tank) -2nd sample Water sample received to our Vakratunda Laboratory on 14/7/2026. Payment details given by TMC Representative i.e. Sample Collected Person is responsible for payment details. This further acknowledges that you have paid the charges Rs. 7020/- vide Receipt No.TMC/LOS/PCC/000020/26-27 dated 22.04.2026

This Report Is Digitally Signed And Approved.